



1826 Kramer Lane, Suite M
 Austin, Texas 78758
 p | 512-926-6650
 f | 512-833-5058
 kleinfelder.com

To: Yarrington Road Materials
 Attn.: Mr. Rick Coleman
 P.O. Box 967
 Kyle, Texas 78640

Project: 2011 Yarrington Road QA

Project No.: 110038
 Date: 09-28-11
 Control No.: 092812 C

Page 1 of 1


REPORT OF: Standard Classification of Soils for Engineering Purposes
 TEST METHOD: ASTM C-702, D-2487-00
 LABORATORY ID#: G-3115
 LOCATION SAMPLED: Foundation Fill
 MATERIAL SAMPLED BY: Client
 DATE RECEIVED: 09-21-11
 TEST PERFORMED BY: T. Weathers, F. Zuniga
 RESULTS:

<u>Sieve</u>	<u>% Retained</u>	<u>Atterberg Limits</u>	
3"	0	Liquid Limit	28
1 3/4"	0	Plastic Limit	13
7/8"	1.9	Plasticity Index	15
3/8"	10.0		
#4	12.6		
#40	20.0		
#200	45.9		

Group Symbol: CL
 Material Color: Tan
 Group Name: Sandy Lean Clay

1-Above

Report Reviewed by: JSD


 Barry Siler, C.E.T.

The results shown on this report are for the exclusive use of the client for whom they were obtained and apply only to the samples tested and/or inspected. They are not intended to be indicative of the qualities of apparently identical products. The use of our name must receive our prior written approval. Reports must be reproduced in their entirety.